



PROVO RIVER
WATER USERS
ASSOCIATION

BOARD OF DIRECTORS

TOM GODFREY, PRESIDENT
CHRISTOPHER R. TSCHIRKI, VICE PRESIDENT
LAURA BRIEFER
JOAN DEGIORGIO
DAN JOHNSON
JOHN S. KIRKHAM
DONALD Y. MILNE
ANNALEE MUNSEY
TOM WARD
JACOB YOUNG
WAYNE WINSOR

JEFFREY D. BUDGE, GENERAL MANAGER

2025 General Master Plan Question & Answer

July 22, 2024

Question 1: In task 4 it references “assess condition.” Some people on my team wondered if that was a full-blown condition assessment where we look at every piece of infrastructure in the whole system or should we plan to do a high-level review? For example, would we look at the pieces in big chunks of your system like Weber Provo Canal, Duchesne Tunnel, PRA, etc. and talk about the overall condition? Or would we be expected to talk about every turnout on the PRA? The check structures in the canal? Etc.

Answer 1: We expect it to be as comprehensive as the 2014 Master Plan Update but include the specific information that we have now (ie. PRA Master Plan, SCADA Master plan).

You should incorporate the PRA Master Plan by reference into the 2025 General Master Plan. The same thing for the SCADA Master Plan. You should not need to go deep into the PRA but should plan on general checks of the pipe and vaults. You may know of things to look at in one vault as far as the electronics, valves, and controls and be able to make a general recommendation on the equipment for all the vaults installed with the original enclosure project, for vaults added after the enclosure project there would be different recommendations as the equipment will vary in age. You should plan on looking into each vault to see if there is anything specific such as leaks, water damage, etc. and make recommendations based on the conditions found.

For the Weber – Provo Canal, again you should look at the SCADA Master Plan for its recommendation, but you will need to look at each structure and update from the 2014 Master Plan update. Some of the recommendation in the 2014 plan have not been completed and should be included in the new update and prioritized into the new recommendations.